



Tech Tip

August 2023

TRANE
TECHNOLOGIES

Safety Concerns

Safety is the most **IMPORTANT** issue to keep in mind!

Never pump down a unit when making a Micro Channel repair on equipment of any type as it could cause seriously bodily harm and even DEATH!!

- Refrigerant should always be recovered according to EPA guidelines.
- Safe practices take time. Be sure to read all warnings and other important information on the install documents.
- Equipment manufactured today do not have service valves, but there are many units still in operation today that do have valves.



Field Service Representative Contact

SW FL 239-277-0344; Option 3

SE FL 954-421-7133; Option 2

N FL 844-358-7263; option 2

Tech Tip

MONTH 2022



Field Service Representative Contact

SW FL 239-277-0344; Option 3

SE FL 954-421-7133; Option 2

N FL 844-358-7263; option 2