



# Tech Tip

2025

## Blower Motors running with NO call

We are hearing of Constant Torque Motors running while in the "OFF" or "NO CALL" state.

This is a result of low voltage bleeding thru from thermostats back to the Air Handler. It takes as little as 7vac to run the motor on Speed Tap 3(only on tap 3).


### Field Fix:

1. Use another Speed Tap other than #3.

### OR

2. Install a SPST relay at AH and Break "G".

This has been found on the TEM4 & 5TEM4 Air Handlers but good information to reference in all A/H's with CTMs.



Field Service Representative Contact

Trane® Technician

1-844-358-7263



Symbio® Service & Installation